

It is the responsibility of each business operator to provide outdoor dining in full compliance with accessibility requirements of the Americans with Disabilities Act (ADA) and the California Building Code (CBC). The checklists below were developed as part of the overall State Street requirements to assist restaurant operators with ADA compliance.

Nothing contained herein shall replace or diminish any of the requirements under the ADA or CBC. Businesses are encouraged to retain the services of a Certified Access Specialist (CASp) to assist in the design and configuration of their facilities. For detailed descriptions of requirements with diagrams, please refer to *Requirements for Operating a Business on the Temporary State Street Promenade*.

Please note that each unique dining area must be in compliance with accessibility requirements. Interior, patio, sidewalk dining, and Outdoor Business Facilities are each required to be in compliance.

### **Ramp**

- Facility is level with sidewalk, no ramp required.
- Facility is *not* level with sidewalk and requires a ramp.
  - Ramp is at least 4 feet wide.
  - Maximum running slope of 8.3% (1:12) and maximum cross slope of 2%.
  - Handrails are required on both sides if ramp slope exceeds 5%.
  - Level landings at top and bottom of ramp measuring at least 4 feet by 4 feet.
  - Unobstructed path of travel, at least 4 feet wide, from sidewalk to ramp.
  - Edge protection on each side of ramp.
  - Ramp must be firm, stable, and slip-resistant.
  - Ramp must be secure to prevent movement or shifting during use.
  - Ramp must not have abrupt vertical edges or variations over 1/2" in height. Edges or changes in height between 1/4" and 1/2" must be beveled to provide a smooth transition.

### **Facility Requirements**

- Vertical clearance (distance to any overhead element, including lighting and umbrellas) must be a minimum of 80 inches.
- Gaps between surfaces (*ex: between curb and platform*) must be less than 1/2"

### **Accessible Seating**

- At least 5% of seating spaces, including tables and counter seating, must be accessible.
- The table or counter surface must be between 28 and 34 inches high.
- The space between the floor and the bottom of the table or counter must be at least 27 inches high.
- Knee clearance must extend at least 19 inches under the table or counter. Knee clearance is measured from the edge of the table or counter to the outside edge of any obstruction under the table or counter, including table legs and bases. Pedestal-style tables are not accessible.
- Table or counter legs, bases, or supports must be at least 30 inches apart, as measured from the narrowest point.
- Each seat must have at least 30 inches by 48 inches of clear floor area and must be at least 4 feet from the nearest obstruction.
- The International Symbol of Accessibility must be displayed at the table(s).
- An accessible path of travel at least 44 inches wide must be maintained to the accessible table(s).