



NOTE: WATER HEATER MUST BE 5 FEET FROM INTERIOR PROPERTY LINE AND SHALL NOT EXCEED 53 dB AT THE PROPERTY LINE. SPEC SHEET DEMONSTRATING NOISE COMPLIANCE MUST BE SUBMITTED WITH FUTURE FULL SUBMITTAL.

